

# Moin!

## Energy analysis by set of rules DWA A-216e

29.11.2022

| Jörg Oppermann | hanseWasser Bremen | Process engineer, Waste water expert  
| Idris Alhababseh | Miyahuna | Head of sewer section, Plant engineer  
| Nina Radtke | hanseWasser Bremen | Team leader process technology


# Agenda

- Our WOP: Who works together and how we work together
- Set of rules DWA A-216e
- WOP result: Energy analysis WWTP Madaba (Jordan)
- Experiences by implementation
- Discussion





Source: [https://www.google.de/maps/place/Deutschland/...](https://www.google.de/maps/place/Deutschland/)



Source: paintmaps.com

## WOP: German-Jordanian Water Operators Partnership


→ Miyahuna (Jordan), hanseWasser and Hamburg Wasser (Germany) started in April 2021 long term partnership for know-how-transfer.



← speakers for this presentation


→ One of the main goals is to make the operation of WWTP more energy-efficient.

## Jordan Water Company Miyahuna





# Hamburg Wasser



## Netze BW Wasser (NWA) - Facts and Figures



Area: **207 km<sup>2</sup>**  
Population: **604.166**



**342 m** height difference



**Network length: 2.526 km**

VW 1.389 km (distribution network)  
AW 1.005 km (household connections)  
ZW 132 km (transportation pipes)



**Connections:** ~ 76.000 pieces  
**Water meters:** ~ 105.000 pieces  
**Fittings** in system: ~17.000 pieces



Amount of **water samples** in supply area:  
**28.200 samples**



Ann. system input volume: ~ **41 Mio. m<sup>3</sup>**




**41 water reservoir**  
at ~ 160 T m<sup>3</sup> Capacity  
**68 pressure zones**



**38 pumping stations** and  
**17 Turbines**  
**>3 million GWh** per year  
**energy recovery**



**costs** per glass of water  
(250 ml): **0,0716 Cent**







1 WWTP Farge



4 Pressure Pipe Findorff



2 Control Center Seehausen



5 Stormwater Basin MVA



2 WWTP Seehausen



6 Main Pumping Station Findorff



3 Headquarter




7 Sewer flow steering Stern

## hanseWasser

### Sewer system

(Mixed and separated Systems)

- 2,200 km sewer network
- 130 km pressure pipes
- 200 pumping stations, Stormwater basins
- Storage volume for stormwater events  
270,000 m<sup>3</sup>
- 230 km Sewer-CCTV-Inspection per year
- Sewer information system
- 700 km sewer cleaning per year
- Operational sewer information system



### Treatment

WWTP Seehausen

1,000,000 Inh

WWTP Farge

160,000 Inh



## Partnership Activities


→ 4<sup>th</sup> Networking Event of the Utility Platform  
30<sup>th</sup>/31<sup>st</sup> of May 2022 in Stuttgart, Germany



→ IFAT Munich 2022



→ Visits on each others plants  
in Germany and Jordan



## Expectations for the WOP

- Strengthen the capacity of human resources to reach improved overall performance of operators and enable them to continue long term improvements once partnerships came to the end.
- Specific technical assistance and training programs in:
  - Energy analysis and energy efficiency
  - Anaerobic sludge treatment and renewable energy (biogas and solar energy)



# Our WOP Approach

# WOP Approach

WOPF		DWA-A 216e	
Year of calculation		2022	
CPD [Cpge Mq]		82.148828494289, 8.82286422248119	
Blind el section		1072	
Range output		158.888	
Total number of stations		108.818	
Total population equivalent [PT]		142.224	
Blind input		108.818	
Blind [meters]		27.888	
Range conversion MTP		1.012,147	
Range conversion MTP		1.012,147	
Range output		1.012,147	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	
Possibility of saving		-	
Water saving		-	
Costs of infrastructure		21.4	



# WOP Approach

Value	Unit	WWTP South Amman	WWTP Madaba	WWTP Farge	WWTP Seehausen
Design capacity	PT <sub>BOD,60</sub>		214,000	160,000	980,000
Total number of inhabitants	PT <sub>COD,120</sub>	155,245	72,088	110,518	854,516
and population equivalents (PT)	PT <sub>BOD,60</sub>	198,250	92,797	143,339	916,067
population equivalents american standard	PT <sub>BOD,65</sub>	183,675	85,658	132,320	845,600
Energy consumption WWTP	kWh/a	11,907,570	2,870,673	2,416,258	22,944,378
Energy consumption aeration	kWh/a	8,794,280	1,578,870	1,513,447	10,848,135
Specific energy demand	kWh/(PT <sub>COD,120</sub> *a)	76.7	39.8	25.3	26.9
Specific energy demand	kWh/(PT <sub>BOD,65</sub> *a)	64.8	33.5	18.3	27.1

# Why DWA-A 216?



## Set of rules DWA A-216

### ➤ **Guidance to reduce energy demand of WWTPs**

- „Energie in ARA“, Bundesamt für Energie, Schweiz, 1994
- Handbuch „Energie in Kläranlagen“, MURL, NRW, 1999
- Leitfaden „Senkung des Stromverbrauchs auf Kläranlagen“ DWA-LV BW, 2008
- „Leitfaden für die Erstellung eines Energiekonzeptes kommunaler Kläranlagen, Wien, 2008

### ➤ **Inventory for WWTPs**

- „Stromverbrauch auf kommunalen Kläranlagen“, LfU, 1998
- „Steigerung der Energieeffizienz auf kommunalen Kläranlagen“, UBA, 2008
- DWA-Leistungsvergleich Kläranlagen, Bad Honnef, 2011

## Set of rules DWA A-216

### ➤ **Conditions for energy efficiency**

- Criteria and reference size?
- Methodology for determining the optimum or for characterizing the best possible energy efficiency?
- Comparability of treatment procedures, concepts, size categories?

### ➤ **Mandate to the DWA:**

- Development of a nationwide instrument for verifying energy efficiency

[Home - DWA - German Association for Water, Wastewater and Waste](#)

# Set of rules DWA A-216

## What is the DWA Set of Rules?



Technical standards are an important factor in efficaciously and economically protecting the environment and material goods and in promoting quality assurance. The DWA therefore incorporates into its standards the most recent findings on time-tested procedures. The DWA Set of Rules consists of

Standards and Guidelines and is prepared by more than 2400 specialists, who are engaged in the association in an honorary capacity and work in more than 340 specialist committees and working groups.

The DWA Set of Rules is viewed in Germany as the general basis for planning, construction and operation of plants in water, wastewater and waste management, as well as in soil conservation. It makes a considerable contribution to keeping the cost of environmental protection at a reasonable level. With this Set of Rules, the associations assume individual responsibility for their specific areas of expertise and unburden the state to a considerable extent: it should be noted that the DIN standards and the rules and standards of the DWA are of equal importance.

[DWA-A 216E \(Energy Check/12/2015\)](#)



# Set of rules DWA A-216

## ➤ Water Quality

### Foreword DWA-A 216

„... In doing so, these efforts to improve the energy efficiency should not contravene the primary purpose of urban drainage, that is discharge and treatment of wastewater with the objective of protecting the waterbodies....“  
(A216, DWA, Dezember 2015)

## ➤ Content divided:

Energy Check

Energy Analysis

# Energy Check

## Example:

WWTP Size category 4 (10,000 – 100,000 Inhabitants)

$$E_{\text{tot}} = 453,079 \text{ kWh/a}$$

$$PT_{\text{COD}} = 10,215 \text{ (120g COD/d = 1 Inhabitant)}$$

$$e_{\text{tot}} = E_{\text{tot}} / PT_{\text{COD}}$$

$$e_{\text{tot}} = 453,079 / 10,215 \text{ [kWh/(Inh*a)]}$$

$$\mathbf{e_{\text{tot}} = 44.4 \text{ kWh/ (Inh*a)}}$$

# Energy Check

## Example:

WWTP Size category 4 (10,000 – 100,000 Inhabitants)

$$E_{\text{aer}} = 220,521 \text{ kWh/a}$$

$$PT_{\text{COD}} = 10,215$$


$$e_{\text{aer}} = E_{\text{aer}} / PT_{\text{COD}}$$

$$e_{\text{aer}} = 220,521 / 10,215 \text{ [kWh/(Inh*a)]}$$

$$e_{\text{aer}} = \mathbf{21.6 \text{ kWh/ (Inh*a)}}$$




# Energy Check



Figures 1 and 2: Specific total power consumption depending on the cleaning process

# Energy Check



Figures 1 and 2: Specific total power consumption depending on the cleaning process

# Energy Check











Figure 3: Specific power consumption of the aeration  $e_{\text{aer}}$  of a wastewater treatment plant



# Energy Check



# Energy Check



# Energy Check

## Further specific values

### **WWTP with digestion:**

- specific digester gas production related to the total number of inhabitants and population Equivalents
- specific digester gas production related to the organic dry mass
- rate of digester gas conversion into electricity
- degree of selfsupply of electricity
- specific external heat consumption

### **Pumping station:**

- specific total power consumption for pumping station



## Summary Energy Check

- ▶ The energy check classifies the waste water treatment plant in comparison to other sewage treatment plants and gives an indication of whether it makes sense to carry out an energy analysis
- ▶ It is a good tool to show long-time effects on energy demand
- ▶ It does not provide any information about ways to save energy
- ▶ A detailed energy analysis is required for specific measures

# Energy Analysis

- ▶ Detailed survey and evaluation of the energy situation based on a complete consumer matrix
- ▶ Derivation of optimization measures
- ▶ Economic evaluation of optimization measures
- ▶ Classification of optimization measures

# Energy Analysis

The measures identified are divided into three priority levels:

- ▶ Immediate measures (S)
- ▶ Short-term measures (K)
- ▶ Dependent Actions (A)

# Energy Analysis

- ▶ **Immediate measures (S)**

Measures that are easy to implement without major investment and planning effort.

- ▶ **Short-term measures (K)**


Measures that are classified as economically and technically feasible in the energy analysis and that are proposed for short-term processing and implementation.

- ▶ **Dependent Actions (A)**

Measures that, due to an unfavorable cost-benefit ratio or other dependencies, can only be implemented as part of new buildings or conversions that are due anyway.



# Energy Analysis




→ Which part of this theoretical potential can actually be leveraged?

# Energy Analysis

- More than 92% of the theoretically potential can be reached by concrete measures
- **21%** of the whole energy consumption of all (German) plants can be saved only by implementing immediate and short-term measures

Mean energetic potential kWh/(l\*a)



- ▶ Immediate measures (S)
- ▶ Short-term measures (K)
- ▶ Dependent Actions (A)

## Summary DWA-A 216e

- The Energy Check by DWA A-216 is a good tool to monitor energy demand and efficiency by defined specific values
- For our WOP (Part Waste Water) these specific values were the starting point to formulate concrete work packages by comparing our WWTPs
- The set of rules DWA A-216 is a good tool to classify the actual energy requirement of a WWTP and to estimate the ideal energy requirement
- There are also other ways to get more energy efficient that could be better for your actual starting point

# **Application of DWA-A 216 on WWTP Madaba**



## Madaba city

→ Population 214,100 people, city is still growing fast

→ Area 1,000 km<sup>2</sup>

→ Sewage Subscribers services

→ total water subscribers in Madaba city is 32,000

→ Sewage subscribers is 20,100 (65%)






# Madaba WWTP + sewer network

## Madaba WWTP



## Madaba Sewer Network



## Madaba WWTP

MWWTP was a lagoon-based treatment system built in 1986

Capacity : 2,000 m<sup>3</sup>/day

In 2002 the plant was expanded and upgraded to biological treatment (secondary)

Capacity : 7,600 m<sup>3</sup>/day

The plant receives wastewater from Madaba city networks (serve 60 %) as well as trucked septage (5%)

**The WWTP Effluent standard is per JS893/2021 category 3c ( field crops )**

## Madaba WWTP - Design & Reference Conditions


Daily Maximum Wastewater Flow	7,600 m <sup>3</sup> /day
Water Treatment	Extended Aeration Activated sludge
Sludge Treatment	Gravity Thickening (Drying Bed)
Treated Water Reuse	Re-use for Agriculture ( field crops )

Parameter	Raw wastewater	Design	Reference (JS893/2006) Category 3-C
BOD <sub>5</sub>	950	50	300
COD		150	500
TSS	1000	50	300
pH		7-9	6-9
T-N	150	50	100
PO <sub>4</sub> -P	40	15	30




# Madaba WWTP - Plant Layout (Process)

6.2 Process block diagram



## Madaba WWTP – Reuse of treated wastewater




1 dunam is 1,000 m<sup>2</sup>.

## Madaba WWTP - challenges


Since 2018, the **daily amount of incoming wastewater exceeded the design capacity** of 7,600 cubic meters per day and is still growing, adversely affecting the quality of treated water and the operational efficiency of the plant and posing a major challenge to the sustainable operation and maintenance of the plant (mechanical and electrical facilities and equipment over 20 years of age).

**High demand of energy**  
required for operation of the  
WWTP  
(50 % of the total cost of  
treatment.)




## Madaba WWTP – energy consumption

Year	Inflow (m <sup>3</sup> )	Energy (kWh)	kWh/m <sup>3</sup>
2021	2,870,401	2,870,673	1.00
2020	2,825,638	3,125,263	1.11
2019	2,651,250	3,094,576	1.17
2018	2,783,308	2,750,040	1.00
2017	2,696,620	3,040,060	1.12
2016	2,592,368	3,126,030	1.21





## On site Madaba WWTP – energy analysis




## What has been done?

- Energy check
- List of aggregates
  - Classification
  - Nominal values
  - Annual Operating hours
  - Measured values
  - Real consumption
  - Calculation of ideal values (not all done yet)
- Comparison real/ideal values (not all done yet)
- Saving opportunities (not all done yet)


# Energy check Madaba WWTP

energy check WWTP			Madaba, Jordan	GK5
1. Basic data		type of plant:	activated sludge process without digester	
population equivalent related to 120gCOD/(PE*d) [inlet of WWTP]	PE <sub>COD</sub>		103.502	PE
total energy consumption (electrical)	E <sub>total</sub>		3.277.128	kWh/a
9 months in 2022 and calculated for 12 months with higher consumption (sewerage)				
electrical energy consumption of the aeration in biological reactor	E <sub>aer</sub>		2.600.000	kWh/a
roughly calculated for 6 months with 5 aerators on high level, 6 months with 8 aerators				

spec. total energy consumption



spec. energy consumption for aeration



# List of aggregates Madaba WWTP

number of aggregates in simulation: 49  
 real consumption: 3592633 kWh/a = 34,71 kWh/(EW\* a)  
 ideal consumption: 14490 kWh/a = 0,14 kWh/(EW\* a)  
 percentage of registration: 109,6%

substitutional values:  
 cos phi: 0,78  
 voltage: 395 Volt

hanseWasser

Nr.	aggregate		group	classification		var x	nominal values				measured values	f <sub>x</sub>	measured values				consumption	consumption				action / optimisation	savings potential (kWh/a)	action number of action	comment
	facility identifier (Nr.)	name/description of aggregate		main group	side group		volt (V)	ampere (A)	cos phi (-)	power (kW)			volt (V)	ampere (A)	power (kW)	power calculated (kW)		operating hours per year (h/a)	real energy consumption (kWh/a)	ideal energy consumption (kWh/a)	target/actual consumption ratio (%)				
1	M-102A	Fine Screen		mechanical treatment	screen		400	3,00	0,75	0,75			395	1,6		0,9		8140	7.326	7.245	101		81		
2	M-102B	Fine Screen		mechanical treatment	screen		400	3,00	0,75	0,75			395	1,6		0,9		8140	7.326	7.245	101		81		
3	M-206 A	Equalization pump		other	general		400	25,00		7,50			395	15,7		8,4		2300	19.320						

→ Every aggregate is listed, classified and the nominal values so as the voltage are written down.

→ The current is measured for every running aggregate.

→ Operating hours and some other values had to be estimated in this case, because not every value is actually recorded. With all those informations, the real energy consumption can be calculated.

- Percentage of registration not so precise, but in a normal zone around 90-110%
- It is yet possible to see, where most of the energy is used.



# Calculation of ideal values

Screen	No. in aggregate list	1	Bezeichnung: Fine Screen - M-102A	
	Specific energy demand	0.07 kWh/m³	Remark:	
	PE (COD120)	103		7,245 kWh/a
spez. Energieverbr. [kWh/(EW*a)]				
Screen	No. in aggregate list	2	0,05 - 0,10 kWh/(EW*a)	
	Specific energy demand	0.07 kWh/m³	Remark:	

25 Inner Circulation Pump - M-203 A				
Selection (x)	Target value		Efficiency Pump + Motor	
x	Screw trough pumps	Raw wastewater		0,50 - 0,60
		Return sludge		0,60 - 0,70
		Internal circuit		0,60 - 0,70
x	Centrifugal pump	Raw wastewater	Vortex wheel	0,45 - 0,55
			Single-channel wheel	0,50 - 0,60
			Multi-channel wheel	0,65 - 0,75
x	Centrifugal pump	Return sludge		0,65 - 0,75
		Outlet (filter feed)		0,65 - 0,75
			Spiral wheel	0,65 - 0,80
x	Propeller pump	Internal circuit		0,65 - 0,80
	Tubular casing pump			0,65 - 0,80
	Eccentric screw pump	Sludge		0,50 - 0,65
Selected target value				0,70
Förderhöhe:				
via theoretical values:				
H <sub>ges</sub>			4,00 m	
H <sub>v</sub>			2,00 m	
H <sub>A</sub>			6,00 m	
via measurement:				
P <sub>suction side</sub>			bar	
Remarks:				
Falsche Eingabe				
Summary for parameters to calculate the ideal value in the aggregate list:				
Delivery head (m)	Delivery rate (m³/h)	Operating hours (h/a)	Efficiency (%)	Ideal consumption (kWh/a)
6,00	480	8240	0,70	91535
<= Link				

Mixer/Agitator	No. in aggregate list	5	Bezeichnung: Anaerobic Mixer - M - 203 A	
	Circulation volume	499 m³	Remark:	
	Specific energy demand	3,5 kWh/m³		
	Number of agitators per tank	8		
spezifische Energieverbräuche				
			4,0-2,5 für V 200-500m³	
			2,5-2,0 für V 500-1000m³	
			1,5-2,0 für V 1000-2000m³	
			1,5 für V >2000m³	
Mixer/Agitator	No. in aggregate list	6		
	Circulation volume	499 m³	Remark:	
	Specific energy demand	3,5 kWh/m³		
	Number of agitators per tank	8		
spezifische Energieverbräuche				
			4,0-2,5 für V 200-500m³	
			2,5-2,0 für V 500-1000m³	
			1,5-2,0 für V 1000-2000m³	
			1,5 für V >2000m³	
Mixer/Agitator	No. in aggregate list	7		
	Circulation volume	499 m³	Remark:	






## Comparison of expected energy and real energy consumption

main group	side group	energy consumption		proportion of total consumption %	specific ideal value for this plant		real / specific ideal value %	savings potential		comments
		kWh/a	kWh/(PE-a)		kWh/a	kWh/(PE-a)		kWh/a	kWh/(PE-a)	
intake	general	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
	pump station	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
	total	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
mechanical treatment	general	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
	screen	14,652	0.1	0.4%	14,490	0.1	101.1%	162	0.0	
	grit/sand chamber	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
	primary clarifier	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
	total	14,652	0.1	0.4%	14,490	0.1	101.1%	162	0.0	
biological treatment	bio-P-removal	123,600	1.2	3.8%	28,794	0.3	429.3%	94,806	0.9	
	denitrification	179,632	1.7	5.5%	43,191	0.4	415.9%	136,441	1.3	
	nitrification	2,541,216	24.6	77.5%	1,800,000	17.4	141.2%	741,216	7.2	
	recirculation	181,812	1.8	5.5%	145,300	1.4	125.1%	36,512	0.4	
	returned activated sludge	141,728	1.4	4.3%	130,000	1.3	109.0%	11,728	0.1	not final
	secondary settlement tank	25,544	0.2	0.8%	25,544	0.2	100.0%	0	0.0	
	total	3,193,532	30.9	97.4%	2,172,829	21.0	147.0%	1,020,703	9.9	
(high water) pump station	general	261,589	2.5	8.0%	209,271	2.0	125.0%	52,318	0.5	not final
sludge treatment	primary sludge	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
	wasted activated sludge	61,900	0.6	1.9%	55,000	0.5	112.5%	6,900	0.1	not final
	digested sludge	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
	total	61,900	0.6	1.9%	55,000	0.5	112.5%	6,900	0.1	
gas treatment	general	0	0.0	0.0%	0	0.0	0.0%	0	0.0	
other	general	60,960	0.6	1.9%	49,881	0.5	122.2%	11,079	0.1	not final
total according to list of aggregates		3,592,633	34.7	109.6%	2,501,471	24.2	143.6%	1,091,162	10.5	
real consumption according to electrical bill		3,277,128	31.7							

# Comparison of expected energy and real energy consumption

Not final for some pumps etc.



## Possibilities for optimisation (excerpt)

### Madaba, Jordan

overview of detected possibilities during energy analysis

price for energy

0.105 JOD/kWh



Measure #	#	Designation	Description of measures	Type	Savings Potential		
					kWh/a	kWh/PE	JOD/a
1	1	Fine Screen	Aggregate runs well. If a new one is needed, choose efficient aggregate.	O	162	0.00	17
2	4	Equalization pump	If a new one is needed, choose efficient aggregate. → <b>pressure loss is still needed!</b>	O	8,870	0.09	931
3	6	Anaerobic Mixer	Aggregates are inefficient. More efficient mixers should be installed. For the two aggregates, savings around 10,000 JOD/a are realistic.	S	94,806	0.92	9,955
4	12	Anoxic Mixer	Only 3 of the 6 Anoxic Mixers are running. Changing these into more efficient aggregates would save around 15,000 JOD/a for energy, compared to the actual situation. If every anoxic basin would get mixed again to operate all 6 basins in a good way, the summed up savings would be even higher when all basins get more efficient mixers.	S	136,441	1.32	14,326

→ There is already thought of necessary expansion of the plant because city is still growing fast... build it energy efficient from the start... Energy analysis might also be useful for these plans.

## Experiences from the energy analysis on Madaba WWTP

- The focus on process- and energy-optimization for WWTPs got bigger in the last few years, due to the fact that Jordan has limited water and energy resources.
- Energy analysis seems to be a useful tool for Miyahuna. We found good options for energy savings on Madaba WWTP.
- Next step should be to implement some of the measures found in the analysis and to see the results.
- There are not many differences between doing the analysis in Germany or in Jordan. Only surface aeration and no measurement of operational hours were a bit different.
- **It is much better to do an analysis like that in direct peer-to-peer-contact and on site. Only meeting each other online and reading the set of rules would not have brought the same good results! We experienced this, because the time of the Covid-pandemic (only online meetings) was not as effective as the visits.**

# Discussion/questions?





# Thanks for your attention

Jörg Oppermann

Process engineer / Waste Water Treatment

[oppermann@hanseWasser.de](mailto:oppermann@hanseWasser.de)